

Government of Bihar

Public Health Engineering Department

Water Quality Report

Division Name: Public Health Engineering Division, Biharsharif & Hilsa

District Name: Nalanda

Sample Collected by :- MUKESH KUMAR SINHA

Date of Sampling :- 16/05/2026

Sl. No.	Block	Panchayat	Village	Habitation	Wd No	Location of Source	Test result													Source of Water
							pH	Turb.	EC	TDS	TH	Ca	Mg	Cl	Alka.	Fe	NO ₃	SO ₄	F	
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21
1	BIHARSHARIF	SAKRAUL	KANCHANPUR	KANCHANPUR	10	UNITY INTERNATIONAL SCHOOL BIHARSHARIF	7.86	0.34	392	255	130	32	12	40	140	0.09	<1.0	10.2	0.645	Tep water
Desirable Limit							6.5-8.5	1	-	500	200	75	30	250	200	1	45	200	1	-
Permissible Limit* in absence of alternate source							NR	5	-	2000	600	200	100	1000	600	NR	NR	400	1.5	-

Chemist
Public Health Division, Biharsharif
(Nalanda)

Bandhu
18/5/26